

# GUIDELINES FOR CONSTRUCTION OF TEMPORARY PEDESTRIAN WALKWAY CANOPY

## GENERAL NOTES:

1. STREET OBSTRUCTION PERMIT IS REQUIRED FOR ALL TEMPORARY WALKWAY IN PUBLIC RIGHT OF WAY.
2. THE TEMPORARY WALKWAY SHALL CONFORM TO THE GENERAL GUIDELINES AND DETAILS SET FORTH IN THESE DRAWINGS (M-4 & M-5). THE WALKWAY MUST CONFORM TO ALL REQUIREMENTS OF CHAPTER 44 "PROTECTION OF PEDESTRIANS DURING CONSTRUCTION OR DEMOLITION" OF THE CURRENTLY ADOPTED UNIFORM BUILDING CODE (UBC).
3. LOCATION PLANS SHOWING ALL EXISTING FACILITIES IN RELATIONSHIP TO THE PROPOSED WALKWAY AND WITHIN 50' OF EACH END OF WALKWAY SHALL BE SUBMITTED WITH ALL PERMIT APPLICATIONS.
4. VISIBILITY OF SIGNS AND ADJACENT DRIVEWAYS OR INTERSECTIONS SHALL BE MAINTAINED. WARNING SIGNS MAY BE REQUIRED.
5. ACCESS TO FIRE HYDRANTS, UTILITY METERS AND POLES, ETC. SHALL BE MAINTAINED. ACCESS TO FIRE HYDRANT SHALL BE MAINTAINED BY MODIFYING THE BUILDING SIDE WALKWAY WALL TO ALLOW FOR 3 FEET CLEAR ACCESS AREA TO HYDRANT. HYDRANT ACCESS DETAILS MUST BE APPROVED BY FIRE MARSHALL.
6. DRAINAGE SHALL BE MAINTAINED THROUGHOUT THE TEMPORARY WALKWAY AREAS.
7. TWO (2) SELF-POWERED FLASHERS SHALL BE INSTALLED AT EACH END OF WALKWAY AND REFLECTORS AT 20' INTERVALS ALONG LENGTH.
8. ALL WALLS AND STUDS VISIBLE TO THE PUBLIC SHALL BE PAINTED WITH WHITE EXTERIOR LATEX PAINT.
9. ALL CHANGES IN GRADE (RAMPING) BETWEEN THE TEMPORARY WALKWAY AND OTHER EXISTING FACILITIES SHALL NOT EXCEED 1:12 SLOPE. RAMPS SHALL BE STRUCTURALLY SOUND, SAFE AND FREE OF ANY POTENTIAL TRIPPING HAZARD.
10. NAILING SCHEDULE SHALL CONFORM TO TABLE 23-II-B-I OF THE 1997 UBC. PLYWOOD SPLICE PLATES SHALL BE NAILED @ 6" MAX O.C.
11. LUMBER SHALL BE DOUGLAS FIR CONSTRUCTION OR BETTER.
12. PLYWOOD SHALL BE C-D EXTERIOR TYPE OR BETTER.

NOTE: THIS PLAN IS NOT A LEGAL ENGINEERING DOCUMENT BUT AN ELECTRONIC DUPLICATE. THE SIGNED CITY OF OAKLAND STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION IS AVAILABLE FOR PURCHASE FROM THE CONTRACT ADMINISTRATION DEPARTMENT.

CITY OF OAKLAND

DESIGN AND CONSTRUCTION SERVICES DEPARTMENT



## GUIDELINES FOR TEMPORARY PEDESTRIAN WALKWAY CANOPY

ENGINEERING DESIGN MANAGER

DATE: JANUARY 2002  
REV. DATE: \_\_\_\_\_

DWG.

M-4